

Mantel Clearances

450mm min. to any protrusion greater than 50mm.

4. MANTELPIECES

- * MUST BE POSITIONED SO THAT A MINIMUM CLEARANCE OF 100mm IS ACHIEVED BETWEEN THE VERTICAL LEGS OF MANTELPIECE AND THE OPENING OF THE FIREBOX AND UNDERSIDE OF MANTELSHELF
- * MUST BE A MINIMUM OF 450mm ABOVE THE TOP OF THE FIREBOX OPENING.