ROOMS WITH GAS OPEN FIRES REQUIRE FRESH AIR VENTS AS PER GAS REGULATIONS

Rooms with gas open fires require fresh air vents as per **Clause 6.10.9.5** in **AS/NZS5601.1: 2013**

One or more ventilation openings with a combined free ventilation area of not less than the equivalent cross sectional area of the flue cowl shall be provided for each decorative flame effect fire, and circulations based on clause 6.4.4.